



## ICF TECHNOLOGY INCORPORATED

### Memorandum

TO: File

FROM: *rn* Alex Zocchi, FIT Chemical Engineer *JS*

DATE: May 11, 1989

SUBJ: Rationale for the Score Sheet for the Houston Light & Power,  
Robinson Generating Station, Bacliff, TX. TDD # F-6-8902-26,  
CERCLIS # TXD000837401, PAN FTX0809PAA.

### Groundwater Route

1. The potential for a release does not exist since the waste is stored in fiberglass lined, concrete above ground tanks which are sound.

### Surface Water Route

2. No documentation of an observed release to the surface water has been found.
3. The potential for a release does not exist since the waste is stored in fiberglass lined, concrete above ground tanks which are sound.

### Air Route

4. No documentation of an observed release to the surface water has been found.
5. A release of hazardous waste to the air is not likely, since ~~most of~~ the waste is non-volatile.

90066991

